

CERTIFICATE OF COMPLIANCE

Certificate Number 20141120-E342628
Report Reference E342628-20111229
Issue Date 2014-NOVEMBER-20

Issued to: OBO BETTERMANN (SHENZHEN) LTD
5F-B 9TH BLDG XIUNAN ST
99 XINXIU VLG
LUOHU DISTRICT
SHENZHEN GUANGDONG 518001 CHINA

**This is to certify that
representative samples of**

COMPONENT - SURGE-PROTECTIVE DEVICES
Type 4 Component Assemblies, Din Rail Modules, VF
Series, Part. No. VF12-AC/DC, VF24-AC/DC,
VF24-AC/DC-FS, VF48-AC/DC, and VF2 Series, Part. No.
VF2-24-AC/DC-FS.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance
capabilities and are intended for use as components of complete equipment submitted for investigation rather
than for direct separate installation in the field. The final acceptance of the component is dependent upon its
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141120-E342628
Report Reference E342628-20111229
Issue Date 2014-NOVEMBER-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

UL 1449 - Standard for Surge Protective Devices
C22.2 No. 8-M1986 - Standard for Electromagnetic Interference Filters
CSA Electrical Certification Notice 516 / CSA Technical Information Letter (T.I.L.) I-11B
Surge/Transient Voltage Surge Suppressors.
C22.2 No. 42-10



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

